



**Drinking Water Quality and Compliance
SaskWater Codette Lake Potable Water Supply System
2019 Notification to Consumers**

The Water Security Agency (WSA) requires that, at least once each year, waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Permit to Operate a waterworks. The following is a summary of the SaskWater Codette Lake Potable Water Supply System water quality and sample submission compliance record for the January 1, 2019 to December 31, 2019 time period. This report was completed on February 10, 2020. Readers should refer to WSA's Municipal Drinking Water Quality Monitoring Guidelines, October 2012, EPB 202 for more information on minimum sample submission requirements and types of samples. Permit requirements for a specific waterworks may require more sampling than outlined in the Agency's monitoring guidelines. If consumers need to know more about drinking water, more detailed information is available from: <http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index-eng.php>.

BACTERIOLOGICAL QUALITY

Parameter	Limit	Regular Samples Required	Required Samples Submitted	# Positive of Regular Submitted
Total Coliform	0 Organisms/100 mL	104	104	0
E. Coli	0 Organisms/100 mL	104	104	0
Background Bacteria	Less than 200/100 mL	104	104	0

Analysis is performed on a single sample for all parameters mentioned above. All waterworks are required to submit samples for bacteriological water quality; the frequency of monitoring depends on the population served by the waterworks.

WATER DISINFECTION

Chlorine Residual in Distribution System – From Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit (either/or)	Range (mg/L)	# Tests Required	# Tests Submitted	# Adequate Chlorine
Free Chlorine	0.1 mg/L	0.64 – 2.67	104	104	104
Total Chlorine	0.5 mg/L	0.91 – 3.02	104	104	

A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual **OR** 0.5 mg/L total chlorine residual is required at all times throughout the distribution system. An adequate chlorine is a result that indicates that the chlorine level is above the regulated minimums. A waterworks is required to submit chlorine residual test results on every bacteriological sample they submit.

Free Chlorine Residual for Water Leaving the Filters

Parameter	Limit (mg/L)	Range (mg/L)	# Tests Required	# Tests Performed	% Adequate Chlorine (%)
Free Chlorine	At least 0.35	0.36 – 0.93	365	731	100

Additional testing is done for informational purposes.

Codette Lake Potable Water Supply System

Free Chlorine Residual for Water Entering the Distribution System

Parameter	Limit (mg/L)	Range (mg/L)	# Tests Required	# Tests Performed	% Adequate Chlorine (%)
Free Chlorine	At least 1.2	1.48 – 3.03	365	Continuous	100

Residuals are monitored continuously and multiple tests are normally performed on a daily basis by waterworks operators and are to be recorded in operation records.

TURBIDITY

Turbidity is a measure of water treatment efficiency. Turbidity measures the “clarity” of the drinking water and is generally reported in Nephelometric Turbidity Units (NTU).

Turbidity in the Distribution System – From Test Results Submitted with Bacteriological Samples

Parameter	Limit (NTU)	Range (NTU)	# Tests Required	# Tests Performed	# Exceeding Limit
Turbidity	No standard	0.06 – 0.22	104	104	0

The turbidity is tested at the same frequency as the bacteriological testing with a bench testing instrument.

Turbidity for Water Leaving the Filter

Parameter	Limit (NTU)	Range (NTU)	95 th Percentile (NTU)	# Tests Required	# Tests Performed	# months Exceeding Limit
Turbidity	< 0.30 – 95% of time each month; cannot be > 0.3 for more than 12 consecutive hours and; never >1.0	0.023 – 0.211	0.075	Continuous	Continuous	0

Turbidity leaving the filters is monitored continuously and multiple tests are normally performed on a daily basis by waterworks operators and are recorded in operation records.

FLUORIDE

Fluoride – From Treated Water at the Water Treatment Plant (on-site testing)

Parameter	Limit (mg/L)	Average (mg/L)	Maximum (mg/L)	# Samples Required	# Samples Submitted	# Exceeding Limit
Fluoride	1.5	0.88	1.20	365	731	0

Additional testing is done for informational purposes.

Fluoride – From Treated Water at the Water Treatment Plant (off-site testing)

Parameter	Limit (mg/L)	Average (mg/L)	Maximum (mg/L)	# Samples Required	# Samples Submitted	# Exceeding Limit
Fluoride	1.5	0.73	0.97	52	52	0

Codette Lake Potable Water Supply System

CHEMICAL – HEALTH

SaskWater Codette Lake Potable Water Supply is required to submit Chemical Health once per year. Additional testing is done for informational purposes.

Parameter	MAC (mg/L)	IMAC (mg/L)	AO* (mg/L)	Sample Results (mg/L)	# of Samples Required	# of Samples Submitted
Aluminum	No Objective			0.022	1	5
Antimony	0.006			<0.0002	1	2
Arsenic	0.010			0.0002	1	2
Barium	1.0			0.047	1	2
Boron		5.0		0.03	1	2
Cadmium	0.005			<0.00001	1	2
Chromium	0.050			<0.0005	1	2
Copper			1.0	0.0080	1	2
Iron			0.3	0.0024	1	2
Lead	0.010			<0.0001	1	2
Manganese			0.05	0.0010	1	2
Selenium	0.010			0.0002	1	2
Silver	No Objective			<0.00006	1	2
Uranium	0.020			<0.0001	1	2
Zinc			5	0.011	1	2

MAC – Maximum Acceptable Concentrations

AO – Aesthetic Objective

IMAC – Interim Maximum Acceptable Concentrations

CHEMICAL – GENERAL

SaskWater Codette Lake Potable Water Supply is required to submit General Chemical once per quarter.

Parameter	MAC	AO*	Sample Results	# Of Samples Required	# Of Samples Submitted
Total Alkalinity (mg/L)		500	121	4	4
Bicarbonate (mg/L)	No Objective		148	4	4
Calcium (mg/L)	No Objective		52	4	4
Carbonate (mg/L)	No Objective		<1	4	4
Chloride (mg/L)		250	15	4	4
Fluoride (mg/L)	1.5		0.88	4	4
Total Hardness (mg/L)		800	204	4	4
Hydroxide (mg/L)	No Objective		<1	4	4
Magnesium (mg/L)		200	18	4	4
Nitrate (mg/L)	45.0		1.4	4	4
pH (pH units)		6.5 - 9.0	7.48	4	4
Potassium (mg/L)	No Objective		5.1	4	4
Sodium (mg/L)		300	24	4	4
Specific Conductivity (µs/cm)	No Objective		507	4	4
Sulphate (mg/L)		500	115	4	4
Sum of Ions	No Objective		378	4	4
Total Dissolved Solids (mg/L)		1500	327	4	4

MAC – Maximum Acceptable Concentrations

AO – Aesthetic Objective

*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards. The aesthetic objectives for several parameters (including hardness as CaCO₃, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

Codette Lake Potable Water Supply System

CHEMICAL – TRIHALOMETHANES (THM)

Trihalomethanes are formed when chlorine reacts with organic matter in water. The four THM compounds are: chloroform, dibromochloromethane, bromodichloromethane (BCDM) and bromoform. The sum of the concentrations of these four components is referred to as Total Trihalomethanes. The limit for THM is a long term objective based on an annual average of seasonal samples.

Parameter	Limit (mg/L)	Average (mg/L)	# Samples Required	# Samples Submitted
Total Trihalomethanes	0.100	0.045	8	8

CHEMICAL – HALOACETIC ACIDS (HAAs)

Haloacetic acids are formed when chlorine reacts with organic matter in water. The five regulated haloacetic acids are: monochloroacetic acid, dichloroacetic acid, trichloroacetic acid, monobromoacetic acid, and dibromoacetic acid. The sum of the concentrations of these five components is referred to as HAA5.

Parameter	Limit (mg/L)	Average (mg/L)	# Samples Required	# Samples Submitted
Haloacetic Acids 5	0.080	0.029	8	8

CHEMICAL – ORGANICS

SaskWater Codette Lake Potable Water Supply System is required to submit water samples for the WSA's Synthetic Organic category once every second year. 2019 is not a required sampling year. The 2018 results are included below for informational purposes.

Parameter	MAC (mg/L)	IMAC (mg/L)	AO* (mg/L)	2018 Sample Results (mg/L)	# of Samples Required	# of Samples Submitted
Benzene	0.005			<0.0005	0	0
Benzo(a)pyrene	0.00001			<0.00001	0	0
Carbon tetrachloride	0.005			<0.002	0	0
Dichlorobenzene 1,2	0.200			<0.0005	0	0
Dichlorobenzene 1,4	0.005			<0.0005	0	0
Dichloroethane 1,2		0.005		<0.0005	0	0
Dichloroethylene 1,1	0.014			<0.0005	0	0
Dichloromethane	0.050			<0.0005	0	0
Dichlorophenol 2,4	0.900			<0.0002	0	0
Ethylbenzene			0.0024	<0.0005	0	0
Monochlorobenzene	0.080			<0.0005	0	0
Nitrotriacetic Acid (NTA)	0.4			<0.1	0	0
Tetrachlorophenol 2,3,4,6	0.100			<0.001	0	0
Toluene	0.05			<0.0005	0	0
Trichloroethylene	0.050			<0.0005	0	0
Trichlorophenol 2,4,6	0.005			<0.002	0	0
Vinyl Chloride	0.002			<0.0005	0	0

MAC – Maximum Acceptable Concentrations

AO – Aesthetic Objective

IMAC – Interim Maximum Acceptable Concentrations

Codette Lake Potable Water Supply System

CHEMICAL – PESTICIDES

SaskWater Codette Lake Potable Water Supply System is required to submit water samples for the WSA’s Pesticide category once every second year. 2019 is not a required sampling year. The 2018 results are included below for informational purposes.

Parameter	MAC (mg/L)	IMAC (mg/L)	2018 Sample Results (mg/L)	# of Samples Required	# of Samples Submitted
Atrazine		0.005	<0.0002	0	0
Bromoxynil		0.005	<0.001	0	0
Carbofuran	0.09		<0.0002	0	0
Chlorpyrifos	0.09		<0.0002	0	0
Dicamba	0.12		<0.001	0	0
2,4-D		0.10	<0.001	0	0
Diclofop-methyl	0.009		<0.001	0	0
Dimethoate		0.02	<0.002	0	0
Malathion	0.19		<0.0002	0	0
MCPA	0.10		<0.001	0	0
Pentachlorophenol	0.06		<0.0005	0	0
Picloram		0.19	<0.001	0	0
Trifluralin		0.045	<0.0002	0	0

MAC – Maximum Acceptable Concentrations

IMAC – Interim Maximum Acceptable Concentrations

CHEMICAL –CYANIDE AND MERCURY

SaskWater Codette Lake Potable Water Supply System is required to submit water samples for the WSA’s Cyanide and Mercury category once every second year. 2019 is not a required sampling year. The 2018 results are included below for informational purposes.

Parameter	Limit (mg/L)	2018 Sample Results (mg/L)	# Samples Required	# Samples Submitted
Cyanide	0.200	<0.001	0	0
Mercury	0.001	0.000004	0	0

More information on water quality and sample submission performance may be obtained from:

SaskWater
 200 - 111 Fairford Street East
 Moose Jaw SK S6H 1C8
 Toll Free: 1-888-230-1111
 Fax: 306-694-3207
 Email: customerservice@saskwater.com